


LogBox 3

Art Nr 460017

PC Interface and LogBox



Pull up and pull down is an option.
Normally it is done in the Assembly
box CVT 2 (through the Jumpers).

The BUS RS485 can be connected by screws (left) or by cable in the RJ10
(4/4) connector. The PC cable is to be connected in the RJ12 (6/6).

By the RJ10 you can connect the BUS to the assembly box into the RJ10. The
assembly box CVT2, Art Nr. 460086 or the CVT3 Art Nr. 460089.